

Memo to File

Date: July 28, 2014

To: File 146 Destructive & Non-Destructive Inspections

From: Denis Houle

RE: Tk 663 Fill lateral between valves Y663, 653,673 at NTF

An eight (8) hour strength test and leak test was performed as per CSA Z-662-11 on the 24'' pipe lateral pipe to fill Tk 663 between closed Valves Y 663,653,673 at NTF.

Test was performed on July 25, 2014 from 18h30 to 16h45. Water was used as the medium.

Test was successful and no failures or leaks were detected.

Test was performed by Denis Houle, Maintenance Supervisor Montreal Terminal.

Instrument used to perform test.

- Dead weight pressure tester used:
Make: Mansfield and Green, Model no. WG-50
Serial no. 5537
- Pressure Recorder used:
Make: Rosemount
Serial no. 1797340
- Temperature Recorder used:
Make: Weksler
Serial no. R96-1959

Signature:  07-28-14

Attachments: Pressure and Temperature log
Hydro test record and certification
Pressure and temperature calibration reports
Copy of pressure and temperature chart.

HYDROSTATIC TEST RECORD AND CERTIFICATION

Test Section: Fill Line Tank 663

Date: 25-Jul-14

Company: Montreal Pipe Line Limited

System: North Tank Field

Description from: Test between valve Y663

To: Valves Y653 & Y673

New Construction: ☐

Requalification: ☒

Replacement or Relocation: ☒

Test Medium Water: ☐

Other: NA

Inhibitor: NA

Design Data Code: ☐ B31.4

☐

B31.3

☒ CSA Z662 - 11

Pipe Design Data

| Specification and Grade | Weld Joint Factor | Design Factor | OD | Wall Thick. | Corr. Allow | Loc. Factor | SMYS | Design Press. | Comments |
|-------------------------|-------------------|---------------|-------|-------------|-------------|-------------|--------|---------------|-----------------------------|
| API 5L -X42 | 1 | 0.8 | 24 | 0.375 | 0.0625 | 1 | 42,000 | 275 | |
| API 5L -X42 | 1 | 0.8 | 30 | 0.375 | 0.0625 | 1 | 42,000 | 275 | |
| A234 WPB | 1 | 0.8 | 30&24 | 0.375 | 0.0625 | 1 | 35,000 | 275 | All Fittings |
| B16.5-A105-Class 150 | 1 | 0.8 | 30&24 | 0.375 | 0.0625 | 1 | 36,000 | 275 | Weld Neck Flanges -ANSI 150 |

Pressure Test:

Test Pressure should be as follows:

Note: maximum test pressure is based on MOP Class 150 Flanges

Minimum at high point: 344 %SMYS 59%

Maximum at Low Point: 450 %SMYS 62%

Elevations: Low Point (Ft): Note 1

High Point (Ft): Note 1

DWT (Ft): Note 1

Qualification:

Date of Test: 25-Jul-14

Duration of Test (hours): 8 hour 15 min

Testing and recording witnessed by: Dennis Houle & Jean Blanchette

Date: 25-Jul-14

Company: Montreal Pipe Line Limited

Company Representative: Dennis Houle

Title: Supervisor

Testing Pressure:

Maximum at low point: 450 PSIG Note: Highest Recorded during test

for %SMYS 62%

Minimum at high point: 381 PSIG Note: Lowest recorded during test

for %SMYS 65%

Qualified to operate at: 275 PSIG Determined by ANSI Class 150 Flanges

for %SMYS 38%

Report checked by:

Date: 25-Jul-14

Approved by:

Title: *Supervisor*

Testing Company: Montreal Pipe Line Limited

Attached Documents:

Pressure record: ☒

Pressure and Temperature Log ☒

Temperature Record: ☒

Sketch and Diagram ☒

Profile: ☐ NA - less than 2 feet

Qualifications Calculations ☐

Failure Record: ☐ NA

Test Instrument Calibration Data: ☒

Comments:

Note 1: Elevation of pipe changes by less than 2 feet from tank inlet valve Y-663 to isolation valves Y652 and Y673

24" diameter pipe used to fill Tk 663 was successfully tested with water between valve 663, 665 and 673. No visual defects or leaks were detected during the 8h 15 minute test. Weather was warm/sunny/hazy day on July 25, 2014.

Test was performed on site at NTF in MTL East by Dennis Houle

Notes:

1. OD = outside diameter, SMYS=specified minimum yield strength, SMY = Specified minimum yield, DWT = deadweight tester
2. For test Sections containing more than one type of pipe, the maximum test pressure at low point and minimum test pressure at high point resulting specified minimum yield strength need to be calculated for each type of pipe.

QUALIFICATION CALCULATIONS

Test Section: Fill Line Tank 663

Date: 25-Jul-14

Company: Montreal Pipe Line Limited

System: North Tank Field

Description from: Test between valve Y663

To: Valves Y653 & Y673

New Construction: ☐

Requalification: ☒

Test Medium Water: ☒ 0.433 psi.ft

Design Data Code: ☐ B31.4

Replacement or Relocation: ☒

Other: NA

Inhibitor: NA

☐

B31.3

☒ CSA Z662 - 11

| <u>ELEVATION</u> | <u>Feet</u> | <u>Pressure</u> | <u>H</u> | <u>L</u> |
|-----------------------------------|-------------|-----------------|----------|----------|
| Location of Deadweight Tester | 324.8 | Read | 450.0 | 381.0 |
| Highest elevation in Test Section | 327.5 | Calc | 448.8 | 379.8 |
| Lowest elevation in Test Section | 324.8 | Calc | 450.0 | 381.0 |

Calculating Minimum High Point SMYS

| Pipe O.D | SMYS | Wall Thick | Corr Allow | WJF | DF | LF | Press | %SMYS |
|----------|-------|------------|------------|-----|----|----|-------|-------|
| 30 | 35000 | 0.375 | 0.0625 | 1 | 1 | 1 | 344 | 58% |

Calculating Maximum Low Point SMYS

| Pipe O.D | SMYS | Wall Thick | Corr Allow | WJF | DF | LF | Press | %SMYS |
|----------|-------|------------|------------|-----|----|----|-------|-------|
| 24 | 35000 | 0.375 | 0.0625 | 1 | 1 | 1 | 450 | 62% |

Test Pressure Results

For Calculations Assume SMYS based on WPB fittings and Actual test pressure

Calculating Maximum at low point %SMYS

| Pipe O.D | SMYS | Wall Thick | Corr Allow | WJF | DF | LF | Press | %SMYS |
|----------|-------|------------|------------|-----|----|----|-------|-------|
| 24 | 35000 | 0.375 | 0.0625 | 1 | 1 | 1 | 450 | 62% |

Calculating Minimum at high Point %SMYS

| Pipe O.D | SMYS | Wall Thick | Corr Allow | WJF | DF | LF | Press | %SMYS |
|----------|-------|------------|------------|-----|----|----|-------|-------|
| 30 | 35000 | 0.375 | 0.0625 | 1 | 1 | 1 | 381 | 65% |

Qualified to operate at %SMYS

| Pipe O.D | SMYS | Wall Thick | Corr Allow | WJF | DF | LF | Press | %SMYS |
|----------|-------|------------|------------|-----|----|----|-------|-------|
| 24 | 35000 | 0.375 | 0.0625 | 1 | 1 | 1 | 275 | 38% |

Flange Pressure Calculation (B16.5-2003 Section 2.6 "System pressure Testing")

B16.5 Version (1996 - 2013: Maximum shell pressure test 1.5 times 100° class rating plus 25 psi

| <u>PSI</u> | <u>X Factor</u> | <u>= psi</u> | <u>Plus psi</u> | <u>Test Pressure (psi)</u> |
|------------|-----------------|--------------|-----------------|----------------------------|
| 285 | 1.5 | 427.5 | 25 | 450 |

Montreal Pipe Line Ltd

Pressure and Temperature Log

Test section Description

Hydro Test on lateral for fill line on TK 663. Test between valves Y 663, 653, 673 at NTF.

Start of Test Period

Time

08:30

Date

July 25 - 2014

End of Test Period

Time

16:45

Date

July 25 - 2014.Pressure test @ 380. for 8 hrs.


| No. | Time | Dead Weight PSIG | Pressure Gauge | Pipe Temp. | Ambient Temp. | By | Remarks |
|-----|-------|------------------|----------------|------------|---------------|----|--------------------------|
| 1 | 08:30 | 380.5 | 381 | 66.7 | 68.1 | DH | Sunny. Start test. |
| 2 | 08:45 | 381.5 | 382 | 66.7 | 68.1 | DH | " |
| 3 | 09:30 | 381.5 | 382 | 67.1 | 67.9 | DH | Hazy. |
| 4 | 10:00 | 382 | 383 | 67.2 | 68.4 | DH | Hazy. |
| 5 | 10:30 | 384 | 384 | 67.4 | 71.0 | DH | Sunny. |
| 6 | 11:00 | 390.5 | 391 | 67.8 | 72.0 | DH | Sunny. |
| 7 | 11:30 | 398 | 398 | 68.0 | 72.6 | DH | " |
| 8 | 12:00 | 405 | 405 | 68.3 | 73.7 | DH | " no leaks. |
| 9 | 12:30 | 412.5 | 413 | 68.7 | 74.2 | DH | " |
| 10 | 13:00 | 425 | 426 | 68.9 | 75.8 | DH | " |
| 11 | 13:30 | 441 | 441 | 69.3 | 76.7 | DH | " |
| 12 | 14:00 | 449 | 450 | 69.6 | 77.8 | DH | " |
| 13 | 14:30 | 449 | 449 | 69.6 | 77.8 | DH | Hazy / cloudy. no leaks. |
| 14 | 15:00 | 448.5 | 449 | 69.5 | 78.1 | DH | " " " |
| 15 | 15:30 | 448.5 | 449 | 69.6 | 78.1 | DH | " " " |
| 16 | 16:00 | 449 | 448.5 | 69.7 | 78.2 | DH | " " " |
| 17 | 16:30 | 448.5 | 448 | 70.1 | 77.8 | DH | " " " |
| 18 | 16:45 | 449.5 | 450 | 70.1 | 77.4 | DH | Sunny. |
| 19 | | | | | | | End of Test. all OK. |
| 20 | | | | | | | |


Test Performed By:

Denis Houle
Print Name

Denis Houle
Signature

07-25-2014
Date





PRESSURE TESTING OF LIQUID PETROLEUM PIPELINES

PRESSURE RECORD

Company Montreal Pipe Line.
System fill lateral on TK 663
between valves 663, 653, 673.

| | |
|---|--|
| Description of Instrument (make/model) <u>Rose mount.</u> | |
| Serial Number of Instrument <u>1797340</u> | |
| Test Section No. <u>24" fill lateral pipe on TK 663 @ NTF.</u> <u>approx. 350 feet</u> miles | |
| MP <u>Y-663</u> to MP <u>Y-653, 673</u> | Station No. <u>NTF</u> to Station No. <u>NTF</u> |
| Location of Chart Recorder MP <u>Near valves 653, 673</u> Station No. <u>NTF</u> | |
| Start Time <u>08:20</u> | Date <u>July 25, 2014</u> |
| End Time <u>16:45</u> | Date <u>July 25, 2014</u> |
| Contractor Rep. <u>N/A.</u> | Title <u>N/A</u> Date <u>N/A</u> |
| Pipeline Company Rep. <u>Denis Houle</u> | Title <u>Supervisor</u> Date <u>07-28-14</u> |
| Project Engineer <u>Miguel Robin.</u> | Date <u>07-28-14</u> |
| Notes: 1. MP = mile post. 2. This pressure information should be included on the permanent record of pressure versus time. Placing this information on a stick-on label and sticking the label to the permanent record might be considered. | |

TEMPERATURE RECORD

Company Montreal Pipe Line.
System Fill lateral on TK 663 between
valves 663, 653, 673.

| | |
|---|---|
| Description of Instrument (make/model) <u>Wetler.</u> | |
| Serial Number of Instrument <u>R-96-1959</u> | |
| Test Section No. <u>24" fill lateral pipe on TK 663 @ NTF.</u> <u>approx 350 feet</u> miles | |
| MP <u>valve 663</u> to MP <u>valves 653, 673</u> | Station No. <u>NTF.</u> to Station No. <u>NTF</u> |
| Location of Chart Recorder MP <u>Near valves 653 and 673</u> Station No. <u>NTF</u> | |
| Start Time <u>08:20</u> | Date <u>July 25, 2014</u> |
| End Time <u>16:45</u> | Date <u>July 25, 2014</u> |
| Contractor Rep. <u>N/A.</u> | Title <u>N/A</u> Date <u>N/A</u> |
| Pipeline Company Rep. <u>Denis Houle</u> | Title <u>Supervisor.</u> Date <u>07-28-14</u> |
| Project Engineer <u>Miguel Robin.</u> | Date <u>07-28-14.</u> |
| Notes: 1. MP = mile post. 2. This temperature information should be included on the permanent record of temperature versus time. Placing this information on a stick-on label and sticking the label to the permanent record might be considered. | |

Montreal Pipe Line Limited

Instrument Check

Honeywell Two Channel Portable Temperature Recorder

Model No. DR45A2-1100

Serial No: 0748Y776363200001

Date: September 5, 2014

Span: 0-100° F

| Applied Temp. ° F | Recorder - ° F | | | |
|-------------------------|----------------------------------|------------|---------|------------|
| | Channel 1 - Process - Purple Pen | | | |
| | Chart | Difference | Display | Difference |
| 40.2 | 40.0 | -0.2 | 40.3 | 0.1 |
| 60.2 | 60.1 | -0.1 | 60.2 | 0.0 |
| 90.0 | 90.0 | 0.0 | 90.4 | 0.4 |

Span: 0-100° F

| Applied Temp. ° F | Recorder - ° F | | | |
|-------------------------|-------------------------------|------------|---------|------------|
| | Channel 2 - Ambient - Red Pen | | | |
| | Chart | Difference | Display | Difference |
| 40.2 | 39.9 | -0.3 | 40.3 | 0.1 |
| 60.2 | 60.0 | -0.2 | 60.3 | 0.1 |
| 90.0 | 90.0 | 0.0 | 90.2 | 0.2 |

Test Instruments Used:

Hart Scientific Dry-well calibrator

Model 9105

Thermometer with probe

Model: Hart Scientific (Fluke) 1521/RTD


Serial No: A73284/800167

Recall Date: 2015-01-29

Performed By: P. M. Dougall

P. M. Dougall

Comments: Instrument check



Montreal Pipe Line Limited

Instrument Loop Check

Honeywell Portable Pressure Recorder

Model No. DR45AT-1100

Serial No: 0722Y7744440500001

and Rosemount Pressure Transmitter

Date: September 5, 2014

Model No: 3051165A1AB

Serial No: 1797340

Span: 0-2000 PSI

| Applied Pressure PSI | Recorder - PSI | | | |
|----------------------------|----------------|------------|---------|------------|
| | Chart | Difference | Display | Difference |
| 0 | 0 | 0 | 0 | 0 |
| 500 | 500 | 0 | 500 | 0 |
| 1000 | 1000 | 0 | 1000 | 0 |
| 1500 | 1501 | 1 | 1500 | 0 |
| 1980 | 1982 | 2 | 1980 | 0 |
| | | | | |

Test Instrument Used:

Ametek Jofra Advanced Pressure Calibrator (APC)

Model: APC03KGINDG


Serial No: 9632072

Recall Date: 2015-04-09

Performed By: P.M.

P. M^cDougall

Comments: Instrument Check



WELLIN
317
TM
line
3TON, PA, U.S.A.

INSTRUMENT CHECK
PORTABLE PRESSURE
RECORDER 0-2,000 PSI
14/09/05

Montreal Pipe Line Limited

Instrument Loop Check

Honeywell Portable Pressure Recorder

Model No. DR45AT-1100
Serial No: 0722Y7744440500001

and Rosemount Pressure Transmitter

Date: April 14, 2014

Model No: 3051165A1AB

Serial No: 1797340

Span: 0-2000 PSI

| Applied Pressure PSI | Recorder - PSI | | | |
|----------------------------|----------------|------------|---------|------------|
| | Chart | Difference | Display | Difference |
| 0 | 0 | 0 | 2 | 2 |
| 500 | 500 | 0 | 502 | 2 |
| 1000 | 1000 | 0 | 1002 | 2 |
| 1500 | 1500 | 0 | 1502 | 2 |
| 1980 | 1980 | 0 | 1983 | 3 |
| | | | | |

Test Instrument Used:

Ametek Jofra Advanced Pressure Calibrator (APC)

Model: APC03KGINDG


Serial No: 9632072

Recall Date: 2015-04-09

Performed By: 

P. McDougall

Comments: Instrument Check



Montreal Pipe Line Limited

Instrument Check

Honeywell Two Channel Portable Temperature Recorder

Model No. DR45A2-1100
Serial No: 0748Y776363200001

Date: April 14, 2014

Span: 0-100° F

| Applied Temp. ° F | Recorder - ° F | | | |
|-------------------------|----------------------------------|------------|---------|------------|
| | Channel 1 - Process - Purple Pen | | | |
| | Chart | Difference | Display | Difference |
| 33.1 | 33.0 | -0.1 | 33.2 | 0.1 |
| 62.0 | 62.0 | 0.0 | 62.2 | 0.2 |
| 90.8 | 91.0 | 0.2 | 91.1 | 0.3 |
| | | | | |

Span: 0-100° F

| Applied Temp. ° F | Recorder - ° F | | | |
|-------------------------|-------------------------------|------------|---------|------------|
| | Channel 2 - Ambient - Red Pen | | | |
| | Chart | Difference | Display | Difference |
| 33.1 | 33.0 | -0.1 | 33.2 | 0.1 |
| 62.0 | 62.0 | 0.0 | 62.0 | 0.0 |
| 90.8 | 91.0 | 0.2 | 90.8 | 0.0 |
| | | | | |

Test Instruments Used:

Hart Scientific Dry-well calibrator
Model 9105

Thermometer with probe

Model: Hart Scientific (Fluke) 1521/RTD
Serial No: A73284/789477
Recall Date: 2015-01-29

Performed By: P. M.

P. McDougall

Comments: Instrument check

